



Wayfinding Signage for the Town of Hanna and the Village of Youngstown

Hanna and Youngstown Signage project
Project no: 0406.5 + 0406.6

Addendum 1

APC Opportunity AB-2022-04882
Closing Date: Wednesday August 17, 2022
Date of Issue: August 9, 2022

1. In the design layout the monument signs call for LED illumination, however, the specs call for fluorescent lamps. Can you please confirm if we are to use LED or fluorescent?
 - A. Please bid with LED.

2. From our experience in designing/fabricating/installing signage all across Alberta, the powder coat spec is going to increase costs drastically and has a risk associated with not being able to fix the sign on site if the powder coat is damaged. Can we spec with a different system?
 - A. We understand that sign manufacturers across Alberta use the Matthews Paint System instead of powder coat. Please bid with the Matthews Paint System.



3. Is there a rubric or grading criteria on which our proposal will be evaluated?
 - A. The main criterion will be cost. Please include information on your company background in the bid.

4. For bidding purposes, what size are the concrete piles for the monument signs?
 - A. Please bid the piles at 18in x 8ft depth (to below frost).

5. The monument signs appear to be too heavy for the break-away supports.
 - A. Value engineering will be required as mentioned in the specifications, but for comparison purposes everyone should bid the same items. Please fill out the bid sheets as per the drawings and specifications. Value engineering alternatives can be included separately as alternative items if desired.

End of Addendum 1